

# City of Henderson Fire Safety Engineering Informational Bulletin

Issue 027

[COHFireSafety@CityofHenderson.com](mailto:COHFireSafety@CityofHenderson.com)

August 23, 2005



## THE RULE OF TWO'S



The Rule of Two's was first established in September 1999. This bulletin is a refresher on how to apply the Rule of Two's.



Deviation(s) from approved plans will require revised drawings to be submitted prior to rough/hydro sprinkler inspection unless the Rule of Two's applies.



### THE RULE OF TWO'S IS HEREBY DEFINED AS:

- Moving any sprinkler head not more than two feet, and/or;
- The addition of not more than two fittings, and/or;
- The addition of not more than two heads within a system.

The intent of this rule is to allow a rough/hydro inspection sign-off without needing to revise plans. However, all changes shall be submitted for review and approval prior to final sprinkler inspection.



Please e-mail comments, questions & suggestions regarding this bulletin to:  
[COHFireSafety@CityofHenderson.com](mailto:COHFireSafety@CityofHenderson.com) or call 702-267-3630

If you do not wish to receive this bulletin, send a reply with REMOVE in the subject line