

City of Henderson Fire Safety Engineering Informational Bulletin

Issue 042

COHFireSafety@CityofHenderson.com

August 29, 2006

CLEAN AGENT SYSTEM Questions and Answers



Q: How many permits are required to install a clean agent system?

A: Two (2). One permit for the mechanical system (Clean Agent F060) and one for the electrical system (Fire Alarm F040).

Q: How much will each permit cost?

A: The F060 permit has a fixed fee of \$1,377 and the F040 permit fee is a function of the number of devices.

Q: How long will the plan review take?

A: The review time is the same for both permit types. The first review will be completed within two weeks. Subsequent reviews are completed within one week.



Q: What inspections are required?

A1: F060 – rough, pneumatic, flow, enclosure and final

A2: F040 – rough, battery and final

Like the Rolling Stones said: "It's a Gas- Gas-Gas"

Please e-mail comments, questions & suggestions regarding this bulletin to:
COHFireSafety@CityofHenderson.com or call 702-267-3630

If you do not wish to receive this bulletin, send a reply with REMOVE in the subject line