

City of Henderson
**Fire Safety Engineering
Informational Bulletin**

Issue 057

COHFireSafety@CityofHenderson.com

June 1, 2007

**1 – 4 DEVICES BY PERMIT TYPE
(EFFECTIVE DATE JULY 2, 2007)**



A **REVISED** process of modifying a sprinkler monitoring system or a fire alarm by 1-4 devices is described below. A helpful Flow Chart is attached.



**F
1
4
0**

The contractor shall obtain a Miscellaneous Fire Protection Equipment Permit F140. An application shall be accompanied by a letter and a product data sheet submitted.

The letter, on Contractor's letterhead, shall include:

- ✓ NAME OF BUSINESS ✓ BUILDING ADDRESS ✓ SUITE #
- ✓ GENERAL CONTRACTOR'S PERMIT # ✓ SCOPE OF WORK



**F
0
3
0**

The fire alarm contractor shall obtain a Fire Alarm TI Permit F030. The application shall be accompanied by plans and product data sheets.
NOTE: Additions to existing fire alarm systems require calculations.

(Currently no fees are collected for permits having 1-4 devices.)

- Q. Do the 1-4 devices include panels?*
A. No. Any work that would require the installation of a fire panel (including monitoring) requires a permit.

Please e-mail comments, questions & suggestions regarding this bulletin to:
COHFireSafety@CityofHenderson.com or call 702-267-3630

If you do not wish to receive this bulletin, send a reply with REMOVE in the subject line