Water Spray Systems

Weekly Inspection

This form covers a 6-month period.						
Year:	System:					
Location:						

General

- 1. If valves are sealed, note "yes" in this block. If any are not sealed, reseal and note "resealed" in this block.
- 2. If all nozzles are in good condition and not blocked, note "yes" in block. If not, see that corrections are made and briefly describe under "notes."
- 3. Assure valve enclosure is maintained above 40°F (4.4°C).
- 4. Assure deluge or preaction valve is free of damage, trim valves are in proper position, and electrical components are operational.
- 5. Record any notes about the system that the inspector believes to be significant.

Date	Inspector	Valves Sealed (1)	Nozzles OK (2)	Alarm Valve OK	Deluge Valve OK (4)	Notes (5)
_						